


LOCKED ROTOR TEST REPORT

Motor Make & Model: MBH	Motor Rated Load [Nm]: 7.66	Power Factor: 0	Number of Poles: 2 Poles
Motor Serial No: 13070006	Motor Rated Voltage [V]: 415	Motor Type: Water-Cooled	Motor rated Efficiency [%]: 0
Motor Rating [kW]: 2.2	Motor Rated Current [A]: 6.5	Supply: 3 Phase	Motor Insulation Class:
Motor Frequency [Hz]: 50 Hz	Motor Rated Speed [rpm]: 2760	Connection Type: DOL	Customer Info:

Torque 
 Current 



LOCKED ROTOR TEST RESULTS:

Breakdown Torque [Nm]: 14.9
Breakdown Current [A]: 14.1
Locked Rotor Torque [Nm] \ Starting Torque: 13.4
Locked Rotor Current [A]:\ Starting Current: 19.11

Approved By: _____

Tested By: _____

Date & Time:

As Per IS 325 & 402

Wed, Jul 24, 2013 2:55 PM